





# Myers<sup>™</sup> Hubs

crouse-hinds COMMERCIAL

PRODUCTS

The broadest, most complete offering for terminating Rigid/IMC to a box or enclosure



## Myers<sup>™</sup> Hubs

## The Original! Often imitated, never duplicated! Available in a wide range of sizes, materials and ratings to meet virtually any customer application!

Myers<sup>™</sup> is the industry leader others have attempted to duplicate but is unparalleled in selection, capability and dependability. In addition to being the most recognized brand of hub on the market, Myers offers larger stainless hub trade sizes, aluminum hubs, ATEX approved hubs, cap-offs, drains, and more!



#### **Applications:**

- Myers hubs are used in the termination of electrical circuits through wall of the enclosure
- Designed for use indoors or outdoors with rigid conduit and IMC
- Ideal for pharmaceutical, chemical and food processing, pulp/paper, nuclear, solar and commercial construction applications
- Suitable for use in environmentally demanding applications, including those with the presence of chemicals, such as acetic, citric and salt water
- Suitable for use in hazardous (classified) locations

#### Features:

- Wide range of styles, trade sizes and materials to meet customer requirements and preferences
- Multiple certifications provide users peace of mind
- · Easy installation and smooth pulling service for labor savings
- Tapered female threads for rigid/IMC conduit, NPSM male threads

#### **Certifications and Compliances:**

- NEC/CEC:
  - Class I. Division 2 Class II, Division 1 & 2 Class III, Division 1 & 2 Class I, Zone 1, AEx e II Class I. Zone 1. Ex e II
- UL Listed UL Standard 514B
- CSA Certified Certified by UL to CSA Standard C22.2 No. 18
- NEMA Type 2, 3, 3R, 4, 4X, 12 (std & ground hub)

#### **Standard Materials:**

- Nut: Zinc (Zamek-2, Zamek-3), Aluminum (Al 360), Stainless (316)
- Body: Zinc (Zamek-2, Zamek-3), Aluminum (Al 360), Stainless (316)

• IEC:

- ATEX Certified to EN60079-0:2009, EN60079-7:2007 and EN60079-14 Standards ATEX Certified ITS12ATEX47591X II 2G Ex e IIC Gb Ta
- (-15°C to120°C)
- IECEX Certified IECEX ETL 12.0009X to IEC 60079-0:2007-10, Edition 5 and IEC 60079-7:2006-07, Edition 4 IECEX-EX e II Gb Ta (-15°C to 120°C)
- IP66
  - **Standard Finishes:** 
    - Aluminum: Natural
    - Zinc: Natural
    - Stainless: Natural

- Insuliner: Lexan
- · O-Ring: Gasket Vi Ton
- Ground Screw: Steel/Stainless Steel





#### Design Features

- A Vibration-proof Strong, oversize nut with radial serrations assures flush installation and positive grounding.
- B Grounding Screw for added safety.
- **Captive O-Ring Gasket** Impervious to corrosive moisture and petroleum products. Gasket assures positive water and dust-tight installations.
- **D** Precision Machine Cut NPT Threads Positive fit and simple installation.
- **E** No Welding Unique serrations on both nut and hub bite into metal assuring a positive electrical ground. (UL approved for use with service entrance conduit).
- Posi-Lok Insulated Throat Cannot come out. Standard in sizes from 1/2" through 4".

#### Hub Basic Scru-Tite®

Hubs are ideal for general use with rigid conduit. Provides positive seal and electrical ground.

Available in

trade sizes

3/8" through 6"



Combines all of the features of

the Hub Basic Scru-Tite® plus the

additional feature of the grounding

**Ground Hub** 

#### **ATEX Rated Hub**

Hub is listed for use in hazardous (classified) locations to IECEx-ATEX certifications. Ideal for global requirements and OEM's shipping material worldwide.



## Through-Bulkhead Fitting

Hubs are the perfect method for installing hubs on cast boxes or through thicker walls.



### Metric to NPT Adapter

Used to convert a threaded metric entry to a NPT entry.



#### **Drain Plugs**

Designed to install in the bottom of an enclosure to drain any accumulated condensation. Available in aluminum or stainless steel construction.



### Cap-Off

Designed to install in enclosure to provide environmental cap for unused entries or knockouts.



## Hub Basic Scru-Tite® NEMA 2, 3, 3R, 4, 4X and 12

#### Zinc

UL File No. E-27258

(JU) .(U)



		Unit	
Cat. #	Size	Qty.	
ST 03†	3/8"	25	
ST 1†	1/2"	25	
ST 2†	3/4"	25	
ST 3†	1"	25	
ST 4†	<b>1</b> <sup>1</sup> / <sub>4</sub> "	10	
ST 5†	<b>1</b> <sup>1</sup> / <sub>2</sub> "	10	
ST 6†	2"	10	
ST 7†	<b>2</b> <sup>1</sup> / <sub>2</sub> "	5	
ST 8	3"	2	
ST 9	<b>3</b> <sup>1</sup> / <sub>2</sub> "	2	
ST 10	4"	2	
ST 11*	5"	1	
ST 12*	6"	1	

†Optional Nickel-Chrome Plate Finish. Add suffix -CP. \*Not supplied with insulator.

## Aluminum

UL File No. E-27258





		Unit
Cat. #	Size	Qty.
STA 1	1/2"	25
STA 2	3/4"	25
STA 3	1"	25
STA 4	<b>1</b> <sup>1</sup> /4"	10
STA 5	<b>1</b> 1/2"	10
STA 6	2"	10
STA 7	<b>2</b> <sup>1</sup> / <sub>2</sub> "	5
STA 8	3"	2
STA 9	<b>3</b> <sup>1</sup> / <sub>2</sub> "	2
STA 10	4"	2
STA 11*	5"	1
STA 12*	6"	1

\*Not supplied with insulator.



## Ground Hub NEMA 2, 3, 3R, 4, 4X and 12

Zinc UL File No. E	-59509	E.G.	Max. Cop Ground V		
Cat. #	Size	Qty.	CSA‡	UL‡	
STG 1	1/2"	25	#8	#8	
STG 2	3/4"	25	#8	#8	
STG 3	1"	25	#8	#8	
STG 4	<b>1</b> 1/4"	10	#8	#8	
STG 5	<b>1</b> 1/2"	10	#6	#8	
STG 6	2"	10	#4	#8	
STG 7	<b>2</b> <sup>1</sup> / <sub>2</sub> "	5	#2	#6	
STG 8	3"	2	1/0	#6	
STG 9	<b>3</b> <sup>1</sup> / <sub>2</sub> "	2	2/0	#6	
STG 10	4"	2	2/0	#4	
STG 11*	5"	1	2/0	#2	
STG 12*	6"	1	3 / 0	#1	
*Not supplied with	*Not supplied with insulator.				

\*Not supplied with insulator. ‡Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.

Aluminum UL File No. E-59509

(U) .(U)



Max. Co	pper	
Ground	Wire	Size

		Unit		
Cat. #	Size	Qty.	CSA‡	UL‡
STAG 1	1/2"	25	#8	#8
STAG 2	3/4"	25	#8	#8
STAG 3	1"	25	#8	#8
STAG 4	<b>1</b> <sup>1</sup> / <sub>4</sub> "	10	#8	#8
STAG 5	<b>1</b> <sup>1</sup> / <sub>2</sub> "	10	#6	#8
STAG 6	2"	10	#4	#8
STAG 7	<b>2</b> <sup>1</sup> / <sub>2</sub> "	5	#2	#6
STAG 8	3"	2	1/0	#6
STAG 9	<b>3</b> <sup>1</sup> / <sub>2</sub> "	2	2/0	#6
STAG 10	4"	2	2/0	#4
STAG 11*	5"	1	3/0	#2
STAG 12*	6"	1	3/0	#1

\*Not supplied with insulator.

‡Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.

## Stainless Steel Type 316

UL File No. E-59509



Max. Copper Ground Wire Size

_		Unit		
Cat. #	Size	Qty.	CSA‡	UL‡
SSTG 1	1/2"	10	#8	#8
SSTG 2	3/4"	10	#8	#8
SSTG 3	1"	10	#8	#8
SSTG 4	<b>1</b> 1/4"	5	#8	#8
SSTG 5	<b>1</b> 1/2"	5	#6	#8
SSTG 6	2"	5	#4	#8
SSTG 7	<b>2</b> <sup>1</sup> / <sub>2</sub> "	2	#2	#6
SSTG 8	3"	2	1/0	#6
SSTG 9	<b>31/2</b> "	2	2/0	#6
SSTG 10	4"	2	2/0	#4

‡Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.



### **ATEX Hazardous Location Hub** with Increased Safety Ground Terminal

NEMA 2, 3, 3R, 4, 4X and IP66

#### ATEX and IEC Ex Approval with INTERTEK SEMKO ITS12ATEX47591X IECEx ETL 12.0009X

### Zinc

 $\langle Ex \rangle$  II 2 G Ex e IIC Gb Ta (-15°C to 120°C) IECEx - Ex e II Gb Ta (-15°C to 120°C)



UL File No. E-187273

Class I, Zone 1, AEx e II Class I, Zone 1, Ex e II

#### Max. Copper Ground Wire Size

Cat. #	Size	Unit Qty.	CSA‡	UL‡
STGK 1	1/2"	10	#8	#8
STGK 2	<sup>3</sup> / <sub>4</sub> "	10	#8	#8
STGK 3	1"	10	#8	#8
STGK 4	<b>1</b> 1/4"	5	#8	#8
STGK 5	<b>1</b> <sup>1</sup> / <sub>2</sub> "	5	#6	#8
STGK 6	2"	5	#4	#8
STGK 7	<b>2</b> <sup>1</sup> / <sub>2</sub> "	2	#2	#6
STGK 8	3"	2	1/0	#6
STGK 9	<b>3</b> <sup>1</sup> / <sub>2</sub> "	2	2/0	#6
STGK 10	4"	2	2/0	#4

 $\ddagger$  Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.

## **Stainless Steel**

(Ex) II 2 G Ex e IIC Gb Ta (-15°C to 120°C)

IECEx - Ex e II Gb Ta (-15°C to 120°C)



Ground Wire Size

Class I, Zone 1, AEx e II

UL File No. E-187273

Class I, Zone 1, Ex e II

Cat. #	Size	Unit Qty.	CSA‡	UL‡
SSTGK 1	1/2"	10	#8	#8
SSTGK 2	<sup>3</sup> / <sub>4</sub> "	10	#8	#8
SSTGK 3	1"	10	#8	#8
SSTGK 4	<b>1</b> <sup>1</sup> / <sub>4</sub> "	5	#8	#8
SSTGK 5	<b>1</b> <sup>1</sup> / <sub>2</sub> "	5	#6	#8
SSTGK 6	2"	5	#4	#8
SSTGK 7	<b>2</b> <sup>1</sup> / <sub>2</sub> "	2	#2	#6
SSTGK 8	3"	2	1/0	#6
SSTGK 9	31/2"	2	2/0	#6
SSTGK 10	4"	2	2/0	#4

‡Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.



## **Through-Bulkhead Fitting**

Zinc UL File No. E-	27258	0	0	
Cat. #	Size	Unit Qty.		
STTB 1	1/2"	5		
STTB 2	3/4"	5		
STTB 3	1"	5		
STTB 4 STTB 5	11/4" 11/2"	5		
STTB 6	1 72 2"	5 5 5 5 5		
STTB 7	2 <sup>1</sup> / <sub>2</sub> "	4		
STTB 8	3"	4 2 2 2		
STTB 9	31/2"	2		
STTB 10	4"	2		
Aluminu UL File No. E-		0	0	
Cat. #	Size	Unit Qty.		
STTBA 1	1/2"	5		
	0/11	-		
STTBA 2	3/4" 1"	5		
STTBA 3	1"	5 5 5		
-		5 5 5 5		
STTBA 3 STTBA 4 STTBA 5 STTBA 6	1" 1 <sup>1</sup> /4" 1 <sup>1</sup> / <sub>2</sub> " 2"	5 5 5 5		
STTBA 3 STTBA 4 STTBA 5 STTBA 6 STTBA 7	1" 1 <sup>1</sup> / <sub>4</sub> " 1 <sup>1</sup> / <sub>2</sub> " 2" 2 <sup>1</sup> / <sub>2</sub> "	5 5 5 5 4		
STTBA 3 STTBA 4 STTBA 5 STTBA 6	1" 1 <sup>1</sup> /4" 1 <sup>1</sup> / <sub>2</sub> " 2"	5 5 5 5		

# Through-Bulkhead Fitting without Nipples

ZINC		constrainty and a second second
UL File No. E	-27258	
JU, JU		
Packaged a	as two pie	ces unassembled
Cat. #	Size	Unit Qty.
STTTB 1	1/2"	5
STTTB 2	3/4"	5
STTTB 3	1"	5 5
STTTB 4	<b>1</b> <sup>1</sup> / <sub>4</sub> "	5
STTTB 5	<b>1</b> <sup>1</sup> / <sub>2</sub> "	5 5
STTTB 6	2"	5
Alumin UL File No. E		
Packaged a	is two pied	ces unassembled
Cat. #	Size	Unit Qty.

Cat. #	Size	Unit Qty.	
STTTBA 1	1/2"	5	
STTTBA 2	<sup>3</sup> / <sub>4</sub> "	5	
STTTBA 3	1"	5	
STTTBA 4	<b>1</b> <sup>1</sup> / <sub>4</sub> "	5	
STTTBA 5	<b>1</b> <sup>1</sup> / <sub>2</sub> "	5	
STTTBA 6	2"	5	

## Myers<sup>™</sup> Hubs

## Metric to NPT Adapter



#### **Zinc**

Cat. #	Size	Unit Qty.
STM 1	M20 to 1/2"	25
STM 2	M25 to 3/4"	25
STM 3	M32 to 1"	25
STM 4	M40 to 11/4"	10
STM 5	M50 to 11/2"	10
STM 6	M63 to 2"	10



### **Stainless Steel**

Cat. #	Size	Unit Qty.	
SSTM 1	M20 to 1/2"	10	
SSTM 2	M25 to 3/4"	10	
SSTM 3	M32 to 1"	10	
SSTM 4	M40 to 11/4"	5	
SSTM 5	M50 to 11/2"	5	
SSTM 6	M63 to 2"	5	

Note: The Myers metric to NPT hub adapter is used to convert a threaded metric entry to a NPT entry. The female thread is NPT and the male thread is metric.

Cap-C	Off		
Zinc UL File No.	E-27258		
Cat. #	Size	Unit Qty.	
STC 1 STC 2 STC 3 STC 4 STC 5 STC 6	1/2" 3/4" 1" 11/4" 11/2" 2"	25 25 25 10 10 10	
Alumir UL File No. ()) ເຫຼິ			
Cat. #	Size	Unit Qty.	
STAC 1	1/2"	25	



### **Aluminum**

UL File No. E-27258 (ŲL) <sub>c</sub>(ŲL)

		SSTC 1	SSTC
Cat. #	Size	Unit Qty.	
STAC 1ST	1/2"	25	
STAC 1CD	1/2"	25	

Note: SSTC 1 and STAC 1ST are for knockouts and are supplied with a locknut and straight threads. SSTC 1CD and STAC 1CD are for threaded openings and are supplied without locknut and NPT threads. Not gasketed to allow for water drainage.

# **Ground Nut**

Zinc

1CD

UL File No. E	E-59509	- 11-1				
(ŲL) "(ŲL)			Max. Copper Grd. Wire Size			
$\mathbf{U}$		Unit	Gru. W	lie Size		
Cat. #	Size	Qty.	CSA	UL		
STGN 1	1/2"	25	#8	#8		
STGN 2	3/4"	25	#8	#8		
STGN 3	1"	25	#8	#8		
STGN 4	<b>1</b> <sup>1</sup> / <sub>4</sub> "	10	#8	#8		
STGN 5	<b>1</b> 1/2"	10	#6	#8		
STGN 6	2"	10	#4	#8		

‡Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.




UL File No. E	-59509	Ca	Max. Copper Grd. Wire Size			
Cat. #	Size	Unit Qty.	CSA	UL		
STAGN 1	1/2"	25	#8	#8		
STAGN 2	3/4"	25	#8	#8		
STAGN 3	1"	25	#8	#8		
STAGN 4	<b>1</b> <sup>1</sup> / <sub>4</sub> "	10	#8	#8		
STAGN 5	<b>1</b> <sup>1</sup> / <sub>2</sub> "	10	#6	#8		
STAGN 6	2"	10	#4	#8		

‡Use of wire terminal is required by CSA & recommended by UL for wire gauges over 10 AWG.



## Dimensions



"D" dimension indicates maximum panel thickness hub will accommodate.

				E		E					K ing Hole)
Size	Α	В	С	D	Min.	Max.	F	G	н	Min.	Max.
3/8	13/2	<b>1</b> 1/8	21/32	1/8	.468	.493	3/8 NPT	3/8 NPSM	60°	43/64	11/16
1/2	<b>1</b> <sup>11</sup> / <sub>32</sub>	<b>1</b> 7/ <sub>16</sub>	<sup>13</sup> / <sub>16</sub>	3/16	.591	.622	1/2 NPT	1/2 NPSM	60°	55/64	7/8
3/4	<b>1</b> <sup>15</sup> / <sub>32</sub>	1 <sup>23</sup> /32	<sup>29</sup> / <sub>32</sub>	3/16	.783	.824	3/4 NPT	3/4 NPSM	60°	<b>1</b> 1/16	<b>1</b> 1/8
1	1 <sup>21</sup> /32	2	<b>1</b> <sup>1</sup> / <sub>32</sub>	1/4	.997	1.049	1 NPT	1 NPSM	60°	1 <sup>21</sup> / <sub>64</sub>	<b>1</b> <sup>3</sup> /8
<b>1</b> 1/4	<b>1</b> <sup>11</sup> / <sub>16</sub>	2 <sup>3</sup> /8	<b>1</b> <sup>1</sup> / <sub>32</sub>	1/4	1.311	1.380	11/4 NPT	11/4 NPSM	60°	<b>1</b> 43/64	<b>1</b> <sup>3</sup> / <sub>4</sub>
11/2	<b>1</b> <sup>11</sup> / <sub>16</sub>	<b>2</b> <sup>3</sup> / <sub>4</sub>	<b>1</b> <sup>1</sup> / <sub>32</sub>	1/4	1.529	1.610	11/2 NPT	11/2 NPSM	60°	<b>1</b> 59/64	2
2	<b>1</b> <sup>3</sup> / <sub>4</sub>	<b>3</b> <sup>1</sup> / <sub>4</sub>	1 <sup>3</sup> /32	1/4	1.964	2.067	2 NPT	2 NPSM	60°	2 <sup>25</sup> / <sub>64</sub>	2 <sup>1</sup> / <sub>2</sub>
21/2	27/32	33/4	<b>1</b> %32	1/4	2.346	2.469	21/2 NPT	21/2 NPSM	60°	2 <sup>57</sup> / <sub>64</sub>	3
3	25/16	4 <sup>3</sup> / <sub>8</sub>	13/8	1/4	2.915	3.068	3 NPT	3 NPSM	45°	<b>3</b> <sup>3</sup> / <sub>64</sub>	35/8
<b>3</b> <sup>1</sup> / <sub>2</sub>	2 <sup>3</sup> /8	5	<b>1</b> <sup>7</sup> / <sub>16</sub>	1/4	3.371	3.548	31/2 NPT	31/2 NPSM	45°	<b>4</b> <sup>1</sup> / <sub>64</sub>	4 <sup>1</sup> / <sub>8</sub>
1	27/16	51/2	<b>1</b> 1/2	1/4	3.825	4.026	4 NPT	4 NPSM	45°	4 <sup>33</sup> / <sub>64</sub>	4 <sup>5</sup> /8
5	2 <sup>15</sup> / <sub>16</sub>	67/8	2	1/4	4.795	5.047	5 NPT	5 NPSM	45°	5 <sup>37</sup> / <sub>64</sub>	511/16
6	3	711/16	2	<sup>5</sup> / <sub>16</sub>	5.762	6.065	6 NPT	6 NPSM	45°	641/64	<b>6</b> <sup>3</sup> / <sub>4</sub>

## **Spacing Chart**

#### **CONDUIT OR PIPE SIZE**

Conduit Size	1/4	3/8	1/2	3/4	1	1-1/4	1-1/2	2	2-1/2	3	3-1/2	4	5	6	
3/8	1-5/32	1-1/4								-				-	
1/2	1-5/16	1-13/32	1-9/16		_					ed squares) conduits b				ie size.	
3/4	1-7/16	1-17/32	1-11/16	1-13/16		_	2. Dimensions in light blue shaded squares are for centers of conduits								
1	1-9/32	1-11/16	1-27/32	1-31/32	2-1/8		_	NOT of the same size. Example: What is the minimum spacing for 2 and %" conduit? Read down column marked 2" to figure opposite %							
1-1/4	1-25/32	1-7/8	2-1/32	2-5/32	2-5/16	2-1/2		and find dimensions is $2^{19}/_{32}$ ".							
1-1/2	1-31/32	2-1/16	2-7/32	2-11/32	2-1/2	2-11/16	2-7/8			inimum spa oximately 1/a					
2	2-7/32	2-5/16	2-15/32	2-19/32	2-3/4	2-15/16	3-1/8	3-3/8	appro		clearance	Detween	JCKING NU	15.	
2-1/2	2-15/32	2-9/16	2-23/32	2-27/32	3	3-3/16	3-3/8	3-5/8	3-7/8	1					
3	2-25/32	2-7/8	3-1/32	3-5/32	3-5/16	3-1/2	3-11/16	3-15/16	4-3/16	4-1/2					
3-1/2	3-3/32	3-3/16	3-11/32	3-15/32	3-5/8	3-13/16	4	4-1/4	4-1/2	4-13/16	5-1/8	1			
4	3-11/32	3-7/16	3-19/32	3-23/32	3-7/8	4-1/16	4-1/4	4-1/2	4-3/4	5-1/16	5-3/8	5-3/4			
5	4-1/32	4-1/8	4-9/32	4-13/32	4-9/16	4-3/4	4-15/16	5-3/16	5-7/16	5-3/4	6-1/16	6-3/16	7-1/8	1	
6	4-13/32	4-1/2	4-21/32	4-25/32	4-15/16	5-1/8	5-5/16	5-9/16	5-13/16	6-1/8	6-7/16	6-11/16	7-3/8	7-3/4	
Minimum s	pace from o	enter of p	ipe or cond	luit to nea	rest obstru	ction.	•		-	-	•				
	19/32	11/16	27/32	31/32	1-1/8	1-5/16	1-1/2	1-3/4	2	2-5/16	2-5/8	2-7/8	3-9/16	3-15/16	

#### For more information: If further assistance is required, please contact an authorized Cooper Crouse-Hinds Distributor, Sales Office, or Customer Service Department.

U.S. (Global Headquarters): Cooper Crouse-Hinds Wolf & Seventh North Streets Syracuse, NY 13221 (866) 764-5454 FAX: (315) 477-5179 FAX Orders Only: (866) 653-0640 crouse.customerctr@cooperindustries.com

Europe (Germany): Cooper Crouse-Hinds GmbH 49 (0) 6271 806-500 49 (0) 6271 806-476 info-ex@ceag.de

China:

Cooper Crouse-Hinds Pte. Ltd. 86-21-2899-3600 FAX: 8-21-2899-4055 cchsales@cooperindustries.com

India: Cooper India Pvt. Ltd. 91-124-4683888 FAX: 91-124-4683899 cchindia@cooperindustries.com

www.crouse-hinds.com Cooper Crouse-Hinds is a registered trademark of Cooper Industries, Inc. ©2012 Cooper Industries, Inc.

Canada: Cooper Crouse-Hinds Canada Toll Free: (800) 265-0502 FAX: (800) 263-9504 FAX Orders Only: (866) 653-0645

Middle East (Dubai): Cooper Crouse-Hinds LLC 971 4 4272500 FAX: 971 4 4298521

Korea: Cooper Crouse-Hinds Korea 82-2 3484-6783 82-2-3484-6778 CCHK-sales@cooperindustries.com Mexico/Latin America/Caribbean: Cooper Crouse-Hinds, S.A. de C.V. 52-555-804-4000 FAX: 52-555-804-4020 mxmercadotecnia@cooperindustries.com

Singapore: Cooper Crouse-Hinds Pte. Ltd. 65-6297-4849 FAX: 65-6297-4819 chsi-sales@cooperindustries.com

Australia: Cooper Electrical Australia 61-2-8787-2777 FAX: 61-2-9609-2342 CEASales@cooperindustries.com

Your Authorized Cooper Crouse-Hinds Distributor is:

Cooper Industries, Ltd. 600 Travis, Ste. 5800 Houston, TX 77002-1001 P: 713-209-8400 www.cooperindustries.com

