

Catalog Number: Item Description: UPC Code:

U4544-XL 100A 1PH 600V TERMINAL 784572230545

Brand Name:	Milbank
Туре:	Wire Termination
Special Features:	Single Phase Three Wire, 10,000 Ampere Short Circuit Current Rating
Application:	Line to Load Distribution Enclosure
Standard:	UL Listed
Voltage Rating:	Up to 600 Volts Alternating Current
Connection:	3 Positionss 12 AWG to 1/0 AWG Line Side Lugs, 3 Positionss 12 AWG to 1/0 AWG Load Side Lugs
Construction:	Type 3R, G90 Galvanized Steel



Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

FEATURE TABLE		
ITEM	QTY	DESCRIPTION
Α	4	STD. MNTG. EMBOSS
В	1	1/4, 1/2 CONC. K.O.
С	1	3⁄4, 1 CONC. K.O.
D	1	1/2, 3/4, 1, 11/4, 11/2, 2 CONC. K.O.
E	1	1, 1¼, 1½, 2 CONC. K.O.







